



October 14, 2014

PRINSCO, INC.
CHATSWORTH FACILITY
RYAN MARCUS
111 E PINE ST.
CHATSWORTH IL 60921

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: PRINSCO, INC.
Product Name: GOLDFLO DUAL WALL
Model Number(s): Pipe: 12, 15, 18, 24, 30 and 36
Fittings: SLEEVE COUPLER & GASKET: 12, 15, 18, 24; CROSS: 12, 15, 18, 24, 30, 36;
ELBOW - 22.5°: 12, 15, 18, 24, 30, 36; ELBOW - 45°: 12, 15, 18, 24, 30, 36; ELBOW - 90°
(2-Part): 12, 15, 18, 24, 30, 36; ELBOW - 90° (3-Part): 12, 15, 18, 24, 30, 36; TEE: 12, 15,
18, 24, 30, 36; WYE - 45°: 12, 15, 18, 24, 30, 36; REDUCER: 12X4, 12X6, 12X8, 12X10,
15X4, 15X6, 15X8, 15X10, 15X12, 18X4, 18X6, 18X8, 18X10, 18X12, 18X15, 24X4, 24X6,
24X8, 24X10, 24X12, 24X15, 24X18, 30X4, 30X6, 30X8, 30X10, 30X12, 30X15, 30X18,
30X24, 36X4, 36X6, 36X8, 36X10, 36X12, 36X15, 36X18, 36X24, 36X30.
All sizes are in inches.
Product File No: 20140299

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2019.

This approval supersedes the approval issued on October 19, 2009 under product file number 20090346.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow
 - c. Stormwater infiltration piping gravity flow perforated
- This product must be labeled with the following information:
 - 1. Manufacturer's name or trademark
 - 2. Date of manufacture
 - 3. National standard to which the pipe meets
 - 4. Nominal size
 - 5. Plant designation
 - 6. Production line

Prinsco Incorporated
October 14, 2014
Page 2 of 2
Product file no.: 20140299

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail